



Government Of West Bengal  
Office Of The Director General  
West Bengal Fire & Emergency Services  
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:FSR/0125186211500051

Date: 26-04-2023

**From:**  
Director  
Fire Prevention Wing,  
West Bengal Fire & Emergency Services

**To: BABLI CHATTERJEE FOUNDATION FOR B.C.M. INTERNATIONAL SCHOOL  
MOUZA - KHRINDA, J.L. NO. - 10, DAG NO. - 347, 347/1876, 419, 420, 421, 421/1720, P.O. - KRISHNAPRIYA, P.S. -  
PINGLA, DIST - PASCHIM MEDINIPUR, PIN - 721140**

**Sub: Fire Safety Certificate for the occupancy of G+II storied three blocks and G+I storied one block Educational building of B.C.M. International School at the premises no. – Mouza- khrinda, J.L. No.- 10, Dag No. 347, 347/1876, 419, 420, 421, 421/1720, P.O.- Krishnapriya, P.S. – Pingla, Dist.- Paschim Medinipur, PIN-721140.**

This is in reference to your application no. 0125189231500033 dated 09-04-2023 regarding the Fire Safety Certificate for the occupancy of G+II storied three blocks and G+I storied one block Educational building of B.C.M. International School at the premises no. – Mouza- khrinda, J.L. No.- 10, Dag No. 347, 347/1876, 419, 420, 421, 421/1720, P.O.- Krishnapriya, P.S. – Pingla, Dist.- Paschim Medinipur, PIN-721140.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

**Recommendation:**

- 1.Entry / Exit, side open space, uses of floors, floor plan etc. as marked and approved from this directorate shall not be changed without prior permission.
- 2.Driveway must be free of any type of obstruction for easy movement for Fire Appliances. No parking will be allowed on the Driveway.
- 3.The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
- 4.To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
- 5.Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them,

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189231500033.

Page : 1



particularly lines above false ceiling & ducts.

6.A fire control room including a closed circuit T.V. system will have to be maintained which observes all floors of the building.

7.The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable places of the Building.

8.The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.

9.Mock Fire Practice and Evacuation Drill shall be performed periodically with participants of all the occupants / staffs of the building.

10.Switch Gear Room and Electrical Rooms shall be protected with automatic fire suppression system confirming relevant I.S. Specification.

11.First-Aid Fire Fighting system shall be provided as per I.S. Specification.

12.Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.

13.A crew of trained fireman under an experienced officer shall have to be maintained round the clock for safety of the building.

14.If required the old electrical lines shall have to be replaced with new lines, the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.

15.Exiting lift shall be used as FIRE LIFT in case of exigencies.

16.Basements shall be used as approved nature of occupancy; storage of inflammable articles shall not be permitted.

17.Refuge areas & access to fire refuge area shall not be obstructed.

18.Gas Bank shall have to be protected as per relevant provision of NBC, Part – IV and IS specification.

19.Fire License shall have to be maintained for storing & processing of L.P.G. & other highly combustible or inflammable articles.

20.Fire Check Doors shall be sealed with rubber sealing properly in order to prevent percolation of smoke.

21.Periodically flashing of water from the water based system shall be made to maintain the efficiency and working performance of the system.

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189231500033.

Page : 2

*D. Poulth*

**MANAGER**  
**BCM INTERNATIONAL SCHOOL**  
Khirinda, Krishnapriya,  
Paschim Medinipur-721140. WB.

*[Signature]*  
**PRINCIPAL**  
**BCM INTERNATIONAL SCHOOL**  
Khirinda, Krishnapriya,  
Paschim Medinipur-721140, WB.  
Aff. No-2430414, Code-16260

22. Emergency light shall have to be provided at the Corridors, Staircases, Exit ways etc. of the Building.

23. Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.

24. Electrical safety audit shall have to be conducted in regular interval and recorded in the proper register and submit this office at time of next renewal.

25. This renewal of 'Fire Safety Certificate' is valid for three year and has to be renewed within validity limit from the date of issue of this letter.

26. Renewal of Fire Safety certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services regarding performance of all the life & Fire Safety arrangements and installations of the building before expiry of validity.

Signature valid

Digitally Signed  
Name: Bam Kundo Chatterjy  
Date: 26-Apr-2023 22:57:45  
Reason: Approved  
Location: West Bengal

Director  
West Bengal Fire & Emergency Services

*D. Paul*  
MANAGER  
BCM INTERNATIONAL  
Khirinda  
Paschim  
16260

*[Signature]*  
PRINCIPAL  
BCM INTERNATIONAL SCHOOL  
Khirinda, Krishnapriya,  
Paschim Medinipur-721140, WB.  
Aff. No-2430414, Code-16260